

C-55

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2024/ 258

Dated:- 22/05/2024

To

The Manager  
M/s Maharani Palace Guest House,  
3461-3556, 3558, 3559, Dariba Pan,  
Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M/s Maharani Palace Guest House at 3461-3556, 3558, 3559, Dariba Pan, Pahar Ganj, New Delhi.

Sir,

This has a reference to Online id no.2024041104720 dated. 26.04.2024, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 13/05/24 in the presence of **Manager** and following shortcomings were observed.

1. CO detectors at each floor are not provided as per gazette notification 27.05.2019.
2. PA system found nonfunctional.

In view of above, the case is rejected and Fire Safety Certificate cannot be renewed. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service  
17/5

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.