

c/6S

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZI 317

Dated:- 06/06/2024

To,

The Manager
M/S ALL IZ WELL Guest House,
4781, Main Bazar Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o ALL IZ WELL Guest House at 4781, Main Bazar Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2024051307470 dated 15 05.24, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 28/05/2024 in the presence of Mr. Ashif Ali and following shortcomings were observed: -

1. Fire Check Door on the staircase are not provided as per Gazette 27.05.2019
2. Hose reel found nonfunctional.
3. CO type detectors found nonfunctional.

Accordingly, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


(Atal Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police(lic), 1st floor, Defence Colony Police Station, New Delhi.