

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/Business/2024/SZ/ 312

Dated: 07/06 /2024

To

The Authorized Signatory,
Bajaj House,
Plot No 97, Nehru Place,
New Delhi 1100019.

Sub: Issuance of Fire Safety Certificate in r/o M/s Bajaj House, Plot No 97, Nehru Place, New Delhi 1100019

Sir,

This is in reference to with Letter, received through outdoor diary no 1049 dated 25/04/2024 on the subject cited above. This is to inform you that the premise was inspected by the concern nominated authority of this department on dated 04-06-2024 in presence of Mr. Vivek Kumar & observed that the building is comprised of Basement, Ground + Mezz. + Five upper floors. During the course of inspection, the following shortcoming observed were noticed:-

1. Automatic fire detection system not provided in some flats.
2. Exit signage found removed at some places.
3. ~~Electrical meter installed under/inside the staircase is not allowed.~~

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer (Bldg) MCD, Jal Vihar, Lajpat Nagar, New Delhi 110024