

C-2

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2024/ 302

Dated: 31/05/2024

To

The Addl. Commissioner of Police,  
Licensing Unit 1st Floor,  
P.S Defence Colony,  
New Delhi-110049

**Subject: - Renewal of Fire Safety Certificate in r/o M/s Gagan Guest House Located at Cottage No. 15, West Patel Nagar, New Delhi-110008.**

Sir,

Please refer to online application No. 2024050606991, dated 07/05/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 24/05/2024 in the presence of Sh. Hasan Parveez (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Fire Check Doors found not provided.
2. Ventilation system found inadequate/ removed.
3. Hose reel hose found nonfunctional.
4. CO detectors found not provided.
5. Automatic sprinkler system found nonfunctional in basement.
6. Terrace pump of 900 lpm capacity found nonfunctional & main valve found closed at terrace.
7. Atrium found covered.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service

O/c  
K  
Patel

Copy to: - The Manager, M/s Gagan Guest House Located at Cottage No. 15, West Patel Nagar, New Delhi-110008.