

c/33



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F6/DFS/MS/School/SZ/2024/ 309

Dated: 07/06/2024

To  
The Principal,  
Ganga Devi Public School,  
E-6, Om Nagar, Meethapur, Badarpur,  
New Delhi-110044.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of **Ganga Devi Public School** located at **E-6, Om Nagar, Meethapur, Badarpur, New Delhi-110044.**

Sir,

With reference to the letter bearing outdoor diary no. 11700 dated 09.01.2024 on the subject cited above, it is informed that the said building was inspected by the officer concerned of this department on 28.05.2024 in the presence of Mr. Mohan Lal (Chairman) and it was observed that school building is comprised of Lower Ground + Upper Ground + 3 upper floors. During the inspection following shortcomings were observed:-

1. Hose reel found not functional.
2. Fire pump found not functional.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.