




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/2024/EH/ 233

Dated 06/06/2024

To

The Joint Commissioner of Police/ Lic,
1st Floor, Licensing Unit, Police Station
Defence Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Govardhan Motels & Restaurant located at Ground Floor, Property No-28/5, Shakti Nagar, Delhi-110007.

Sir,

This has reference to online mha portal I'd. No. 2024051207392 dated: 14.05.2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 29.05.2024 in the presence of Mr. Rajiv Sharma (Manager) to verify the fire safety measures installed in the building and observed that the building is comprised of ground & first floors but restaurant is running at ground floor only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

- 1 There are two exit doors having width of 2.30m & 1.50m provided. The second exit door is also not qualifying the requirement of safe means of escape as this escape route is passing through the kitchen area of the restaurant.
- 2 Terrace level fire water tank capacity of 20,000ltrs is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.
- 3 Standby power supply is not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of restaurant is at your own risk & responsibility.

Yours faithfully


(Atul Garg)
Director
Ph: 011-23414000
