

c/37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/School/SZ/2024/ 303

Dated 31/05/2024

To,

The Principal,
Govt. Girls Sr. Sec. School,
Jharoda Kalan, New Delhi- 110072.

Sub: - Regarding renewal of fire safety certificate in r/o Govt. Girls Sr. Sec. School (Id 1822066) located at Jharoda Kalan, New Delhi- 110072.

Sir,

Please refer to your letter No. GGSSS/JHK/2024/70 dated 04.05.2024, on the subject cited above. In this connection, it is to inform you that the above said school building was inspected by the officer concerned of this department from safety point of view on dated 27.05.2024 in presence of Dr. Neelam Rani (Principal).

During the course of inspection found that the school building having two blocks, old block comprised of ground floor only and new block is comprised of ground plus three upper floors. However, the following shortcomings have been observed: -

- 1 First Aid hose reels/Hydrants found provided but not functional at new block.
- 2 Terrace Fire pump Capacity of 450 LPM found provided but not functional at new block.
- 3 Exit signage found removed.

Keeping in view of above, issuance of fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

The Director of Education, GNCT of NCT of Delhi, Old Secretariat- 110054.