

238

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/School/SZ/2024/ 310

Dated 07/06/2024

To,

The Principal,  
Govt. Sarvodaya Bal Vidyalaya No. 01,  
Tilak Nagar, New Delhi- 110018.

Sub: - Regarding renewal of fire safety certificate in r/o Govt. Sarvodaya Bal Vidyalaya No. 01 located at Tilak Nagar, New Delhi- 110018.

Sir,


Please refer to your letter No. SBV/No.-1/TN/2024/205 dated 09.05.2024, on the subject cited above. In this connection, it is to inform you that the above said school building was inspected by the officer concerned of this department from safety point of view on dated 24.05.2024 in presence of the Principal.

During the course of inspection found that the school building comprised of four blocks namely Main Building Block, Primary Block, Auditorium Block & New block. Main Building block is having ground floor plus two upper floors, Primary block is having ground floor plus one upper floor, Auditorium block is having ground floor only & New block having ground plus three upper floors. However, the following shortcomings have been observed: -

- 1 First Aid hose reels found provided but not functional in New block.
- 2 Terrace Fire pump Capacity of 450 LPM found provided but not functional at New blk.
- 3 Exit signage found not provided.

Keeping in view of above, issuance of fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

The Director of Education, GNCT of NCT of Delhi, Old Secretariat- 110054.