

c/38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2024/ 314

Dated: 07/06/2024

To

Ms Shveta Sachdeva (HOS),
Govt. Sarvodaya Kanya Vidyalaya,
Dayanand Road, Darya Ganj, Delhi -02.

Sub:- Regarding renewal of Fire Safety Certificate in r/o Govt. Sarvodaya Vidyalaya, Dayanand Road, Darya Ganj, Delhi - 02.

Sir,

This has reference to email dated 20.05.2024 & letter outdoor diary no. 1889 dated 20.05.2024 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was visited by officer concerned from this department on 30.05.2024 in the presence of Ms Shveta Sachdeva (HOS) and it was observed that the building is divided into four blocks (Main block, Secondary block, Primary block and Auditorium block). The school had been issued shortcomings vide letter no. F6/DFS/MS/School/2014/1536 dated 01.07.2014 (copy enclosed) are applicable for auditorium block only and the same has not been complied till date. Use of Primary block has been discontinued by the school hence the same has also not been considered. During the inspection of Main Block & Secondary Block, following shortcomings were observed:-

1. Fire extinguishers provided but non functional.
2. Exit signages are not adequately provided.
3. Domestic LPG cylinder cannot be used in home science lab for any purpose.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,


(Atul Garg)

Director o/c

Delhi Fire Service

Tel: 011-23414000

se U 31/5
3/5

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi