

C-67

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ 294

Dated: 31/05/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

**Subject: - Renewal of Fire Safety Certificate in r/o M/s Guest House Paradise Inn
Located at 15A/49, WEA Karol Bagh, New Delhi-110005.**

Sir,

Please refer to online application No. 2024050807192, dated 08/05/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 28/05/2024 in the presence of Sh. Rahul (Receptionist) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Fire Check Doors found not provided.
2. Hose reel hose found nonfunctional.
3. MOEFA and PA system found not nonfunctional.
4. Terrace pump of 450 lpm capacity found nonfunctional
5. Atrium found covered.
6. Basement found closed could not be inspected.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Atul Garg)

Director
Delhi Fire Service

O/c


28/5/24

Copy to: - The Manager, M/s Guest House Paradise Inn Located at 15A/49, WEA Karol Bagh, New Delhi-110005.