

4147

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/GH | 289

Dated: 30/05/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o M/s Hotel Sri Nanak Contiental Guest House Located at 2218-2222 Hardhyan Singh Road, Karol Bagh, New Delhi.

Sir,

Please refer to online application No. 2024032203498, dated 09/05/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 24/05/2024 in the presence of Sh. Naveen Kumar (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Fire Check Doors found not provided.
2. CO detectors found not provided
3. MOEFA found nonfunctional
4. Terrace pump of 900 lpm capacity found nonfunctional on auto mode.
5. Basement found closed could not be inspected.
6. Tin shed found erected at terrace.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Anil Garg)
Director
Delhi Fire Service
o/c
20/05/24

Copy to: - The Manager, M/s Hotel Sri Nanak Contiental Guest House Located at 2218-2222 Hardhyan Singh Road, Karol Bagh, New Delhi.