

C-3

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 318

Dated:-06/06/2024

To,

The Manager,  
M/S Hotel Worth, Guest House,  
Plot no. 02; Block no. 80-A,  
Krishna Market, Pahar Ganj,  
New Delhi.

**Sub: Regarding renewal of FSC in r/o M/S Hotel Worth, Guest House located at Plot no. 02, Block no. 80-A, Krishna Market, Pahar Ganj, New Delhi.**  
Sir,

This has reference to your online ID No. 2024051507564 dated 15/05/24, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 28.05.2024 in presence of Manager and following shortcomings were observed:

1. Fire Check door are not installed as per gazette notification 27.05.2019.
2. CO detectors are not installed as per gazette notification 27.05.2019.

In view of above, the case is rejected and FSC issued earlier vide letter no. F6/DFS/MS/GH/NDZ/2021/131 dated 10.03.2021 shall stand Null & void.

Yours faithfully,

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.