

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/2024/SZ/ 316

Dated: 10 / 06 / 2024

To

Ms. Sonali Rastogi,  
Industrial building at Plot No 41,  
Okhla Industrial Estate, Phase -III, New Delhi

Sub.-: Regarding issuance of Fire Safety Certificate in r/o Industrial building at Plot No 41, Okhla Industrial Estate, Phase -III, New Delhi

Sir,

This has reference to your letter no nil dated 09/05/2024, received through outdoor diary no 2109 dated 28/05/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 04.06.2024 in the presence of Mr. Vijay Kumar to check the compliance of fire safety arrangements installed in the building from fire safety point of view and following shortcomings/ observations made are as under:

1. Smoke management systems provided but found nonfunctional.
2. The pressurization of staircase, lift lobbies non functional.
3. Exit signage's found removed at strategic locations.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE