

4/28

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 2024/ 291

Dated: 30/05/2024

To,

The Manager  
"J" Joy Guest House at 16/67-68, 2<sup>nd</sup> floor,  
Faiz Road, Karol Bagh, New Delhi - 05.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S "J" Joy Guest House at 16/67-68, 2<sup>nd</sup> floor, Faiz Road, Karol Bagh, New Delhi - 05.**

Sir,

This has reference to on line ID No. 2024050306808 dated 03/05/24, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 21/05/24 in the presence of care taker and following shortcomings were observed: -

1. Hose reel & pump found nonfunctional.
2. Co- detector found nonfunctional.
3. Test certificate of FCD is also required to be submitted.

Hence, Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)  
DIRECTOR

Delhi Fire Service

Copy to:

Addl. Commissioner of Police( lic), 1st floor, Defence Colony Police Station, New Delhi