

C-69

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 2024/ 316

Dated:- 06/06/2024

To,

The Manager
M/s K.M International Guest House,
7978, A.K. Road, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o K.M International Guest House at 7978, A.K. Road, Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2024050506928 dated 15.05.2024, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 27/05/24 in the presence of Manager and following shortcomings were observed: -

1. Co- detectors & Smoke management system are not provided as per Gazette notification 27.05.2019.
2. Hose reel found nonfunctional.
3. Auto start pump found nonfunctional.

Hence, the case is rejected. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police(lic), Ist floor, Defence Colony Police Station, New Delhi.