

C-86

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 2024/ 314

Dated:- 06/06/2024

To,

The Manager
M/s Maharaja Continental Guest House,
8194-96, Arakashan Road, Pahar Ganj,
New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Maharaja Continental Guest House at
8194-96, Arakashan Road, Pahar Ganj, New Delhi**


Sir,

This has reference to on line ID No. 2024051707695 dated 17.05.24, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 27/05/24 in the presence of Manager and following shortcomings were observed: -

1. Fire Check doors, smoke management & CO detector are not provided as per gazetted notification dated 27.05.2019.
2. PA system found nonfunctional.
3. Pump is not in auto start provision.

Hence, the case is rejected . Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police(lic), Ist floor, Defence Colony Police Station, New Delhi.