

c/14

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/School/2024/ 317

Dated: 07/06/2024

To,

The Principal,  
P. A. V. Public School,  
K-2/18-19, Budh Vihar-I,  
Delhi-110086.

**Sub:** Issue of FSC in r/o P. A. V. Public School, K-2/18-19, Budh Vihar-I, Delhi-86.

Sir,

Kindly reference to letter received in this department through outdoor diary no. 1653 dated 13.05.2024 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 29.05.2024, in presence of **Mr. Ashok Sharma (Chairman)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Alternate iron staircase found removed.
2. Fire extinguishers are not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

  
(Anil Garg)  
DIRECTOR

Ph; 011-23414000

*an*  
*garg*