

c/07

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 2024/ 307

Dated:-31/05/2024

To,

The Head Of School,
Sh. Phool Chand Vaish,
Senior Secondary School,
New Delhi.

**Sub: Regarding issuance of FSC in r/o Sh. Phool Chand Vaish, Senior Secondary School,
New Delhi.**

Sir,

This has reference to letter no. SPCVSSS/Fire Safety Cer./2024-25/04 dated 23/04/24, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 17.05.24 in the presence of Ms. Manisha (HOS) and following shortcomings were observed.

1. 02 staircases of 1.5 meter each are required to be provided.
2. Hose reel & pump of 450 LPM are not provided.
3. Overhead tank of 10,000 liter is not provided.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,


(Anil Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.