

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/NDZ/2024/ 323

Dated:-10.06.2024

To

Authorized Signatory,
Plot No.-5, Block-II, B block,
Middle Circle, Connaught place, New Delhi.

**Sub:- Regarding renewal of FSC/NOC in r/o Building at Plot No.-5, Block-II, B block,
Middle Circle, Connaught place, New Delhi.**

Sir,

This has reference to your letter no. nil dated nil & DFS diary no. 1911 dated 21.05.2024, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 03/06/2024 in the presence of Sh. Kailash Joshi and the following shortcoming were observed:-

1. Detector found nonfunctional at upper floors and found removed at ground floor.
2. PA system found nonfunctional.
3. Exist signage found removed.

In view of above shortcomings, the application for issuance of fire safety certificate is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/zalicensing authority may take suitable action as deemed fit.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. Medical Health Officer, NDMC, Palika Kendra, New Delhi.