



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/Industrial/NDZ/2024/ 311

Dated: 7/06/2024

To,

Mr. Praveen Kumar Jain (Owner),  
Plot no. 184, Patparganj Industrial Area,  
Delhi - 110092.

**Sub: - Regarding grant of Fire Safety Certificate in r/o Praveen Kumar Jain located at Plot no. 184, Patparganj Industrial Area, Delhi – 110092**

Sir,

This has a reference to your Outdoor Diary No. 1792 dated 16/05/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 31.05.2024 in the presence of Mr. Praveen Kumar Jain (Owner) and observed that building comprised of basement, stilt, ground plus two upper floors only.

**Following shortcomings were observed during time of inspection:**

1. Staircases are not segregated on ground floor.
2. Exhaust fan not provided in basement and upper floors.
3. Terraces pump is 450 LPM against the requirement of 900 LPM.
4. Overhead tank of 10,000 liters capacity is provided against the requirement of 20,000 liters.
5. Lift is going to basement and lift lobby is required on each floor.
6. Lift Pressurization fans provided but not functional.
7. Lift signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, 419 Udyog Sadan, Patparganj Industrial Area, Delhi - 110092.