

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/Business/2024/SZ/ 324

Dated: 10/06/2024

To,

The Authorized Signatory,
Punj Lloyd House, 17-18 Nehru Place,
New Delhi-110019

Sub: Regarding renewal of Fire Safety Certificate in r/o Punj Lloyd House, 17-18
Nehru Place, New Delhi-110019.

Sir,

This is in reference with letter no nil dated 15/05/2024, received through outdoor diary no 1756 dated 15/05/2024 on the subject cited above. In this connection, this is to inform you that the premise was inspected by the concern nominated authority of this department on 04/06/2024 in the presence of Mr. Shemsher Singh (Manager) to verify the compliance of fire prevention and fire safety measures required under the rules. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Smoke management system provided but found nonfunctional.
2. Detection system at 3rd floor is not working.
3. Exit Signage found removed.
4. Temporary structure at terrace level is not allowed.
5. There is a renovation work is under progress in a flat at 3rd floor of the building.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE