

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 2024/ 313

Dated:- 06/06/2024

To,

The Manager,  
M/s Ratan Deep Lodging House,  
7864/3A, J-7879, Arakashan Road,  
Pahar Ganj, New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o Ratan Deep Lodging House, 7864/3A, J-7879, Arakashan Road, Pahar Ganj, New Delhi.**

Sir,

This has reference to on line ID No. 2024051707698 dated 17.05.24, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 27/05/24 in the presence of Manager and following shortcomings were observed: -

1. Co- detectors & Smoke management system are not provided as per Gazette notification 27.05.2019.
2. Auto start pump found nonfunctional.

Hence, the case is rejected. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police( lic), 1st floor, Defence Colony Police Station, New Delhi.