



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-06  
75  
DFA+FE  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/BNQT/NDZ/2024/ 75  
To,

Dated: 05/06/2024

Mr. Kuldeep Bhadauria (Owner),  
Red Coral Hospitality  
Shop no. G-25 & G-29,  
Cross River Mall, CBD Ground,  
Shahdara, Delhi - 110032.

**Sub: - Regarding grant of Fire Safety Certificate in r/o Red Coral Hospitality located at Shop no. G - 25 & G - 29, Cross River Mall, CBD Ground, Shahdara, Delhi -110032.**

Sir,

This has a reference to your MHA Application no. 202405106582 dated 08/05/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 30.05.2024 in the presence of Mr. Kuldeep Bhadauria (Owner) and observed that building comprised of two basement + ground + 03 upper floors only. (Banquet Hall is Ground floor only).

**Following shortcomings were observed during time of inspection:**

1. Two Exit doors of width 2.0 meters and 1.05 meters are provided instead of required width of 2.0 & 1.50 meters.
2. Fire check door not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of police (Lic.), Ist Floor, P.S Defence Colony, New Delhi-24  
w.e.f. - MHA portal ID - 202405106582 dated 08/05/2024.