



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

177
7
भारतीय
अग्नि प्रोत्साहन

No. F6 /DFS/MS/GH/SZ/2024 /323

Dated: 10/6/2024

To

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P S Defence Colony, New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s R.K.G. Divine Inn located at 7-B, Taimoor Nagar, Maharani Bagh, New Friends Colony, New Delhi-65.

Sir,

With reference to the MHA online application I.D. no. 2024032803725 on the subject cited above, it is informed that the said guest house was inspected by Assistant Divisional Officer (M. Road) from this department on 05.06.2024 in the presence of Mr. Sunil Gandhi (Manager) and it was observed that the building is comprised of Basement + Ground + 03 upper floor. During the inspection the following shortcomings were observed:

1. Fire Check Door (FCD) not provided.
2. CO detectors not provided in every room and common areas.
3. Provision of exhaust in atrium not provided.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

05/6/24 M