

C/8 ✓

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

Dated: 30/05/2024

No. F.6/DFS/MS/GH/2024/SZ/ 286
To

The Addl. Commissioner of Police,
Lic/Unit, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Royal Castle Grand located at D-616, D-Block,
C.R Park, New Delhi-110019 .

Sir,

This is in reference with **MHA Portal ID 2024042305910 dated 16/05/2024** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 24.05.2024 in the presence of Mr. Sunil Verma (owner) of the Guest House. During the inspection, it was observed that the Guest House is running Ground + Three Upper Floors. The shortcomings observed are as below:

1. Fire check door not provided in basement.
2. Smoke management system not provided as per clause 7.31 of UBBL 2016.
3. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE