

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/CGHS/SZ/2024/ 318

DATED: 10/06/2024

To,

The President,
Shivalika CGHS Ltd.
Plot No 16, Sector - 09, Dwarka,
New Delhi 110077.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Shivalika CGHS Ltd. Located at Plot No 16, Sector - 09, Dwarka, New Delhi 110077.

Sir,

Please refer to your letter No. nil, dated-10/05/2024 on the subject cited above. In this connection it is to inform to you that the above said residential building has been re-inspected by the officer concerned of this department on 04/06/2024 in the presence of Mr. Premchand Sharma (Society member) from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. The internal road around the building found encroached / blocked.
2. Terrace found locked.
3. Fire extinguishers found removed at some places.
4. Hose reel hose and hydrants found damaged.
5. MOEFA found nonfunctional.
6. Communication system in lift car found removed.
7. Dully fill form J & K are not submitted

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter. The occupancy of the building premises without valid Fire Safety Certificate is on the risk and responsibility of the management committee.

Yours faithfully,


(Atul Garg)
(Director)
Delhi Fire Service
01/6/24

Copy to:-

1. The Joint Director (Building), DDA, Vikas Sadan, INA, New Delhi.