

C19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F.6/DFS/MS/NDZ/2024/ 282

Dated: 29/05/2024

To,

The Manager,  
M/s Vanson Pride 2310/2311/2312/ Plot no. 25,  
Khasra no. 535 Laxmi Narayan Street, Chuna Mandi,  
Pahar Ganj, New Delhi.

**Subject:- FSC (Fire Safety Certificate) in in r/o M/s Vanson Pride 2310/2311/2312/ Plot no. 25, Khasra no. 535 Laxmi Narayan Street Chuna Mandi, Pahar Ganj, New Delhi.**

Sir,

This has a reference to ID No. 2024042205820 dated 30.04.24, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned of this department on 15/05/24 in the presence of **Mr. Gagan Talwar** and following shortcomings were observed:

1. Fire Check doors not provided in basement for compartmentation.
2. Hose reel found non functional.
3. Pump found non functional.
4. PA system not provided.

Therefore, the case is rejected with a request to rectify the shortcomings for further consideration in the matter.

Yours faithfully,

(Ajul Garg)

**DIRECTOR**

Delhi Fire Officer

Copy to :-

The Jt. Commissioner of police ( Lic) Ist Floor , Defense Colony Police Station , New Delhi.