



No. F6/DFS/MS/C.C/NDZ/2024/ 139

Dated: 05/06/2024

To,

The Manager  
Vidypeeth (Physics Wala)  
Building No. 06, New Rajdhani Enclave,  
Delhi - 110092.

**Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Vidypeeth (Physics Wala) located at Building No. 06, New Rajdhani Enclave, Delhi - 110092.**

Sir,

This has a reference to your Outdoor Diary No. 1476 dated 08.05.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 21/05/2024 in the presence of Mr. Parmjeet Singh Yadav (Owner) & Mr. Anupama (Manager) and observed that building comprised of basement (Store), Ground plus three upper floors only.

**Following shortcomings were observed during time of inspection:**

1. The width of corridor is 1.0 meter against the requirement of 1.50 meters.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

ok DELHI FIRE SERVICE  
(u)

Copy to: -

1. The Manager, Vidypeeth (Physics Wala) located at Building No. 06, New Rajdhani Enclave, Delhi - 110092.