

c/55

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2024/ 331

Dated: 12/06/2024

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Al-Tauheed Guest House situated at 3371-72-73 and 3374, Netaji Subhash Marg, Darya Ganj, Delhi-06.**

Sir,

This has reference to online application I.D. no. 2024013101061 dated 22.05.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned from this department on 03.06.2024 in the presence of Mr. Dilip Kumar (Manager) and it was observed that building is comprised of Ground + 04 upper floors. During inspection, following shortcomings were observed:

1. CO detectors with panel and alarm system provided but not functional.
2. Exit signages are not adequately provided.
3. Occupancy at fourth floor is not allowed as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,

  
(Atul Garg)

Director o/c  
Delhi Fire Service  
Tel: 011-23414000

**Copy to:-**

The Licensee,  
Al-Tauheed Guest House at 3371-72-73 and 3374, Netaji Subhash Marg, Darya Ganj, Delhi -06.