



c/99

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/WZ/School/2024/ 319

Dated: 12/06/2024

To,

The Principal
Babson (PSB) Educational Society,
F-19, Sector-08, Rohini,
Delhi-110085.

Sub: - Regarding issuance of fire safety certificate in r/o Babson (PSB) Educational Society, F-19, Sector-08, Rohini, Delhi-110085.

Sir,

Kindly reference to online e-mail dated 15.05.2024 received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 27.05.2024, in presence of Mr. Jile Singh (Care-Taker) to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Terrace Fire pump with capacity of 900 LPM provided but not functional. Therefore, other fire protection systems couldn't be checked & considered non functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules
[/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

Yours faithfully

(Atul Garg)
DIRECTOR

Ph; 011-23414000

Ok
WZ