



F6/DFS/MS/Hospital/NDZ/2024/ 334

Dated: 15/06/2024

To,

Dr. Mamta Jajoo (Head of Office, CNBC),
Chacha Nehru Bal Chikitsalaya,
Geeta Colony, Delhi – 110031.

Subject: - Regarding grant of Fire Safety Certificate in r/o Chacha Nehru Bal Chikitsalaya, located at Geeta Colony, Delhi – 110031.

Sir,

This has a reference to your outdoor dairy no. 2317 dated 31/05/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 08/06/2024 in the presence of Dr. Anil Agarwal (Senior Doctor), Dr. Praveen & Mr. Satuik (JE/PWD) and observed that building comprised of basement, ground plus five upper floors.

1. First –Aid Hose reels provided but not functional.
2. Fire Detection and Alarming System provided but not functional.
3. MOEFA provided but not functional.
4. Internal Hydrants provided but not functional.
5. Yard Hydrants provided but not functional.
6. The fire Pump is not on auto mode.
7. Exit & floors Signage's not provided in strategic location in the building
8. Lift Pressurization fans provided but not functional.
9. Lift signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3rd floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi – 110032.