

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/Hospital/2024/SZ/ 332

Dated: 14/06/2024

To,

Assistant Engineer (E) HSW-2,
PWD EMESD South West,
DDU Hospital Hari Nagar, New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o DDU Hospital, Hari Nagar, New Delhi-110064.

Sir,

This has reference to your letter No. F.No. 9(2)/AE(E)/HSW-2/PWDHMESD/DDUH/ 2024-25/10 dt. 22.05.2024, on the subject cited above. In this connection, it is to inform you that the inspection of above said hospital building has been carried out by officer concerned of this department on 04.06.2024 in the presence of Sh. Parshant (JE Elect.).

During the course of inspection, it was observed that the hospital building Comprised of OPD & Admin block (ground plus one upper floor), OT block (ground plus two upper floors), Trauma & New ward block (ground plus five upper floors), Old Ward block (basement, ground plus seven upper floors). However, the following shortcomings were observed: -

1. Road all around the hospital building was found blocked.
2. Hose reels/Hydrant nozzle found removed.
3. Heat/Smoke detectors and alarming system found removed at some places.
4. Automatic sprinkler system found not provided in new oxygen plant.
5. Exit Signages found removed at some places.

Keeping in view of above, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings for taking further action as necessary for renewal of Fire Safety Certificate.

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Medical Director, D.D.U Hospital, Hari Nagar, New Delhi-110064.
2. The Executive Engineer (E) PWD HSW DAP Lines, Vikas Puri, New Delhi- 18.