



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 337

Dated: 14/06/2024

To

The Principal
Govt. Sr. Sec. Special School for Boys
With Blindness at Sewa Kutir, Delhi-09

Sub: - Regarding grant of fire safety certificate in r/o Govt. Senior Secondary Special School for Boys With Blindness located at Sewa Kutir, Delhi-110009.

Sir,

Please refer to your letter No- GSSSSBB/2023-24/116 dated 20.05.2024 on the subject cited above. In this connection this is to inform you that the above mentioned school building was inspected by the officer concerned of this department on 06.06.2024 in the presence of Dr. J.L. Sharma (Principal) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the school building is comprised of ground & first floor only. The observations/ shortcomings made are as under:-

1. There is only one staircase is provided width of 1.25m against the requirement of 1.50m or and additional staircase 75cm.
2. The fire extinguisher is not provided in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.