



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

c/104



NO. F-6/DFS/MS/WZ/2024/GH/329

Dated:- 12/06/2024

To,

Sh. Vijay Pal Singh,  
M/s. Hotel Royal Miraz  
WZ- 107 A & B, Rishi Nagar,  
Rani Bagh, Delhi- 110034.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Hotel Royal Miraz located at WZ  
107 A & B, Rishi Nagar, Rani Bagh, Delhi- 110034.

Sir,

Please refer to MHA application ID 2024050907267 dated 15.05.2024 on the subject cited above. In this connection it is to inform you that the above said guest house was inspected by the officer concerned of this department on 03.06.2024 in presence of Sh. Paras Kalra to see the compliance of required fire safety measures in the building.

During the course of inspection it has been observed that guest house building is comprised of Basement, Ground plus Three upper floors. Following shortcomings were observed during the course of inspection.

- 1 Smoke ventilation system of basement found removed.
- 2 First Aid Hose reel provided but not functional.
- 3 Carbon monoxide detectors found removed from some rooms.
- 4 MOEFA found provided but not functional.
- 5 Terrace level pump found provided but not functional.
- 6 Temporary structure found on terrace shall be removed.

In View of the above, the application for renewal of Fire Safety Certificate is not considered at this stage and rejected. You are requested to re-apply on MHA portal after compliance of above said shortcomings.

Yours faithfully

(Atul Garg)

Director

Ph: 011-23414000

Copy to:-

1. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> Floor, Police Station, Defence Colony, New Delhi- 110049.
2. MHA Portal ID No. 2024050907267.