

C-51

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/ 332

Dated: 14/06/2024

To,

The Principal,
Govt. Co- Ed. Senior Secondary School,
Sector -06, Site-II,
New Delhi – 110075.

Subject: Renewal of Fire Safety Certificate iro Govt. Co- Ed. Senior Secondary School, (ID-1821031) Located at Sector -06, Site-II New Delhi – 110075.

Sir,

Please refer to your letter no. GCOED/SSS/DWK/S-VI/42, dated 20/05/2024 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 10/06/2024 in presence of Dr. Seema Bhardwaj (Principal) from fire safety point of view.

During the course of inspection the following shortcoming are observed.

1. Hose Reel Hoses found nonfunctional.
2. Terrace pump of 450 LPM capacity found non functional.
3. Overhead fire water tank of 10000 ltr capacity found empty.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
OK ✓
11/6/24

Copy to:-

The, Directorate of Education Old Secretariat Delhi – 110054