

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2024/ 331

DATED: 14/06/2024

To,

The Principal,
Indian Institute of Health Management Research,
Plot No. 03, Pkt HAF, Sector – 18A, Dwarka, New Delhi.

Subject: - Renewal of Fire safety Certificate in r/o Indian Institute of Health Management Research Located at Plot No. 03, Pkt HAF, Sector – 18A, Dwarka, New Delhi.

Sir,

Please refer to your email, dated 24/05/2024 on the subject cited above. In this connection it is to inform to you that the above said building has been re-inspected by the officers concerned of this department on 06/06/2024 in presence of Sh. Sujaram (Sr. manager) from fire safety point of view.

During the course of inspection followings shortcomings are observed:-

1. Exhaust fans found removed in basement.
2. Hoses & branches found missing at some places.
3. Automatic fire detection and alarming system found nonfunctional.
4. Terrace pump found nonfunctional & main valves found closed.
5. Communication system in lift car found removed.
6. All the pumps at ground level found nonfunctional on auto mode.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation with this department for further consideration in the matter.

(Atul Garg)
(Director)
Delhi Fire Service