

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/FH/2024/SZ/ 325

Dated: 13 / 06 / 2024

To

The Joint Commissioner of Police,
Lic/Unit 1st Floor PS Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Lata Greens Khasra No., 296/2, 297/2, 298/2, 298/3, 299 & 347 Village-Sultanpur, New Delhi 110030.

Sir,

This has reference to with **MHA Portal ID 2024051407482** dated **14/05/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 10.06.2024 in the presence of Mr. Harshit Kumar to verify the fire safety measures installed in the building and observed that the Farm House comprised of Basement, (Sealed by owner) and Ground floor only. Accordingly fire safety arrangement were tested / checked and found following observation:

1. The First Aid Hose reel provided but found non-functional.
2. The Internal Hydrant provided but found non-functional.
3. Fire Fighting pumps are provided but found non-functional.
4. Exit signage's found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)

DIRECTOR

DELHI FIRE SERVICE