



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/48



No. F6/DFS/MS/2024/School/ 320

Dated: 12/06/2024

To

The Principal
Nalanda Modern Public School
Sant Nagar, Main Road, Burari, Delhi-84.

Sub:-Regarding grant of fire safety certificate in r/o Nalanda Modern Public School located at Sant Nagar, Main Road, Burari, Delhi-110084.



Sir,

Please refer to your letter received through online e-mail dated 18.05.2024 on the subject cited above. In this connection this is to inform you that the above mentioned school building was inspected by the officer concerned of this department on 06.06.2024 in the presence of Sh. Pradeep Vats (Care Taker) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the school building is comprised of 02 blocks, A- block, comprised of basement + ground + 03 upper floor & B- block, comprised of ground + 03 upper floor only. The observations/ shortcomings made are as under:-

1. Hose reel hose is provided but not functional & short in no's.
2. PA system is provided but not functional.
3. Internal hydrant is provided but not functional & some hydrant found damaged/leakage condition.
4. Terrace level fire water tank is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.
5. Exit signage's and floor signage found removed at some strategic location in the building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully


(Atul Garg)
Director
Ph:-011-23414000


Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.