



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/CC/ 330

Dated: 4/06/2024

To

Sh. Rahul Kalra
Plot No- B-1/1, Model Town,
Part-II, Delhi-110009

Sub: - Regarding issuance of fire safety certificate in r/o Coaching Centre, Plot No- B-1/1, Model Town, Part-II, Delhi-110009.

Sir,

Please refer to your letter no. Nil dated 06.06.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 08.06.2024 in the presence of Sh. Narendra Kalra (Owner) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the educational building (coaching centre) is comprised of basement, stilt, upper ground & 03 upper floors only. The observations/ shortcomings made are as under:-

1. There is only 01 staircase of 1.50m is provided from basement to terrace level against the requirement of one more staircase width of 1.50m from basement to terrace level.
2. Fire check doors not provided.
3. The width of class room doors is 01m against the requirement of 1.20m
4. First aid hose reel hose is not provided.
5. MOEFA system is not provided.
6. Sprinklers system is not provided in the basement & stilt floor.
7. Terrace level fire pump capacity of 900lpm is not provided.
8. Terrace level fire fighting water tank capacity of 10,000ltr is not provided.
9. Exit signage and floor signage not provided at strategic locations in the educational building (coaching centre).

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the abovementioned shortcomings under intimation to this department; till such time running of educational building (coaching centre) is at your own risk & responsibility.

Yours faithfully


(Atul Garg)
Director

Ph-011-23414000

dc 4/24