GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI **HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/ 2024 318

Dated: 12 / 06 /2024

To,

The Principal, Presidium Punjabi Bagh, Shri Narender Charitable Trust, 11/77, West Punjabi Bagh, New Delhi: - 110026.

Sub: - Inspection report in respect of Presidium Punjabi Bagh (Shri Narender Charitable Trust), Located at 11/77, West Punjabi Bagh, New Delhi: - 110026.

Sir,

With reference to your Email dated 15/05/2024 on the subject cited above. In this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 30/05/2024 in the presence of Sh. Neeraj Kumar (Admin) to see the functioning of the fire safety equipments provided in the building.

During inspection, it has been observed that the School comprised of Basement + Ground + 03 upper floors. Fire safety arrangements such as, Fire Extinguishers, First-Aid Hose reels, Internal Hydrant, Pumping arrangements, Terrace pump, etc. are provided in the building.

However, following shortcomings were observed: -

- 1. Width of the staircase is provided 1.52m, 1.25m & 1.20 to 1.5m against requirement of 1.5mt.
- 2. Fire Check door found removed at some places.
- 3. First Aid Hose reels & Internal Hydrant are provided but not functional.
- 4. Automatic sprinkler system is provided but not functional.
- 5. Terrace fire pump of 450 lpm is provided but not functional.
- 6. Overhead water storage tank capacity of 15,000ltr is found empty.
- 7. Exit signage's found removed at some palaces.

In view of above shortcomings, the application for issuance Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,

Copy to:-

1. The Director, Directorate of Education Old Secretariat Delhi - 110054.