



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/30  
7  
आप्लादीव  
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024/ 327

Dated: 12/06/2024

To

The Principal,  
S.S. Khalsa Senior Secondary School (ID- 1925195),  
Lajpat Nagar- IV, New Delhi-24.

**Sub:-** Regarding issuance of Fire Safety Certificate in r/o S.S. Khalsa Senior Secondary School (ID- 1925195), located at Lajpat Nagar- IV, New Delhi-24.

Sir,

With reference to email letter dated 27.05.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 06.06.2024 in the presence of Mr. Neeraj (Guard) and it was observed that the building is comprised of Ground + 1 upper floor. During the inspection following shortcomings were observed:-

1. Fire Extinguishers found not adequate & available Fire Extinguishers found non-functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

07/6/24 M

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.