



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/44



No. F6/DFS/MS/2024/School/ 328

Dated: | 2 / 06 / 2024

To

The Principal
Tagore International Public School
Gali No. 6, Sangam Vihar, Wazirabad, Delhi-84.

Sub: - Regarding grant of fire safety certificate in r/o Tagore International Public School located at Gali No. 6, Sangam Vihar, Wazirabad, Delhi-110084.

Sir,

Please refer to your letter No-Nil dated 24.05.2024 on the subject cited above. In this connection this is to inform you that the above mentioned school building was inspected by the officer concerned of this department on 06.06.2024 in the presence of Sh. B.P Sharma (Manager) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the school building is comprised of ground & first floor only. The observations/ shortcomings made are as under:-

1. Hose reel hose provided but not functional.
2. Terrace level fire pump capacity of 220lpm is provided but not functional.
3. Terrace level fire water tank 2500ltr found removed.
4. Exits signage found removed at strategic location in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully



(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

2/6