

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/Motel/2024/SZ/ 326

Dated: 13/06/2024

To
The Joint Commissioner of Police,
Lic/Unit 1st Floor PS Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of Fire Safety Certificate in r/o The Claremont (unit of Fountainhead Motels Pvt Ltd) Kh. No 559 By MG Road, Aya Nagar, New Delhi 110030

Sir,
This has reference to with **MHA Portal ID 2024042906369 dated 15/05/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 10.06.2024 in the presence of Mr. Sanjeev Kumar (Manager) to verify the fire safety measures installed in the building and observed that the Motel Building comprised of Basement and Ground floor only. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The First Aid Hose reel provided but found non-functional.
2. Automatic sprinkler system provided but found non-functional.
3. The Internal & Yard Hydrant provided but found non-functional.
4. Electrical Fire Pump capacity 2280 LPM, Diesel Engine Pump 2280 LPM and Jockey Pump 180 LPM found removed.
5. Overhead tank capacity 3,000 letters provided against the required capacity of 15,000 ltrs.
6. Exit signage's found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
