

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/FH/2024/SZ/ 339
To

Dated: .18./06.../2024

The Addl. Commissioner of Police,
Lic/Unit, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s New Vasu Garden (Unit of Sat Kartar Caterers)
at Chattarpur Main Road, Chandanhulla Village, New Delhi-110074

Sir,

This is in reference with **MHA Portal ID 2024051607653 Dated 16.05.2024** on the subject cited above. In this connection, this is to inform you that the officers concern of this department visited the premise on 10/06/2024 in the presence of Mr. Himanshu to carry out the inspection in accordance with the provision contained in Rule 33 of Rules 2010. At the time of visit the authorized / responsible person was not available at site hence; the inspection of the premise could not be conducted.

The office concerned of this department has already been visited the premise on 15/05/2024 and issued certain observations / shortcomings vide letter of even no 268 dated 17.05.2024. The following observation.

1. First Aid hose reel provided but found nonfunctional.
2. Internal hydrant provided but found nonfunctional.
3. Fire fighting pumps provide but found not working.
4. Terrace tank could not be checked due to not accessibility of tank.
5. The Exit Signage found removed.

The same observations has already been issued and communicated earlier by this department vide letter of even no 177 dated 09/04/2024.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE