

c/72

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

NO. F6/DFS/MS/SZ/2024/Sch. | 339

DATED: 18/06/2024

To,

The, Principal,
OPG World School,
Sector 19B, Dwarka, New Delhi - 110075.

Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o OPG World School, Located at Sector 19B, Dwarka, New Delhi - 110075.

Sir,

Please refer to your Email dated 05-06-2024 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officer concerned of this department on 12/06/2024 in presence of Sh. Subhash Pandey (Estate Manager) from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. Fire Check Doors found not provided.
2. Smoke management system not interlinked with MOEFA in basement.
3. Hose reel hose & hydrants found nonfunctional.
4. Manually operated fire alarm system (MOEFA) found nonfunctional.
5. Public address system found nonfunctional.
6. Main pump of 2280 lpm jockey pump of 180 lpm and standby pump of 2280 lpm at ground level found nonfunctional.
7. Dimension of Under Ground Fire water storage tank of 200000 litres capacity & terrace tank of 2500ltrs capacity not provided.
8. Terrace pump of capacity 900 lpm found nonfunctional.
9. Exit signage found not provided at some places.
10. Pressurization of Lift Shaft found nonfunctional.
11. PA System Panel, Battery backup & Building Floor Plans in fire control room found not provided.

In view of the above shortcomings issuance of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation to this department for further consideration in the matter


(Atul Garg)
(Director)
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054