

C-86

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

No.F6/DFS/MS/SZ/2024/ 341

Dated: 14/06/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o M/s. Pitrashish Premium Guest House (A unit of Pitrashish Aashrya Pvt. Ltd.) Located at Ground, 1st, 2nd & 3rd floor 59/36, New Rohtak Road, Karol Bagh, New Delhi-110005.

Sir,

Please refer to online application No. 2024051907816, dated 19/05/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 12/06/2024 in the presence of Sh. Deepak Kumar(Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. MOEFA found nonfunctional.
2. Ventilation system found inadequate/nonfunctional.
3. Kitchen found running at terrace in tin shed and it is not shown in the plan. The kitchen must be removed.
4. Terrace pump found nonfunctional on auto mode.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service
014
13/6/24

Copy to: - The Manager, M/s. Pitrashish Premium Guest House (A unit of Pitrashish Aashrya Pvt. Ltd.) Located at Ground, 1st, 2nd & 3rd floor 59/36, New Rohtak Road, Karol Bagh, New Delhi-110005.