



No. F6/DFS/MS/School/NDZ/2024/ 341

Dated: 18/06/2024

To,

The Manager,
Shishu Niketan Public School,
B-Block, Shivaji Road, North Ghonda,
Delhi -110053.

Sub: - Regarding grant of Fire Safety Certificate in r/o Shishu Niketan Public School located at B-Block, Shivaji Road, North Ghonda, Delhi -110053.

Sir,

This has a reference to your email dated 04/06/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 10/06/2024 in the presence of Mr. Ved Prakash (Manager) and observed that building comprised of ground plus one upper floor.

Following shortcomings were observed during time of inspection:

1. Fire Extinguishers not provided.
2. First-Aid-Hose Reel provided but not functional.
3. Fire pump of 220 LPM provided but not functional.
4. Overhead tank capacity 25,00 liters not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c (u) DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Manager, Shishu Niketan Public School located at B-Block, Shivaji Road, North Ghonda, Delhi - 110053.