

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



Dated 14/06/2024

No.F6/DFS/MS/2024/EH/241

To

The Joint Commissioner of Police/ Lic,  
1<sup>st</sup> Floor, Licensing Unit, Police Station  
Defence Colony, New Delhi.

Sub: - Regarding renewal of fire safety certificate in r/o M/s Shivam Foods located at Ground & First Floor, B-79, GTK Road, Ind Area, Delhi-110033.


Sir,

This has reference to online mha portal I'd. No. 2021101424209 dated: 30.05.2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 08.06.2024 in the presence of Mr. Tarun (Manager) to verify the fire safety measures installed in the building and observed that the building is comprised of basement, ground & 02 upper floor but restaurant is running at ground & first floor only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. Hose reel hose is provided but not functional.
2. MOEFA system is provided but not functional.
3. PA system is provided but not functional.
4. Sprinklers system is provided but not functional.
5. Internal hydrant & yard hydrant is provided but not functional & badly damaged/leakage condition.
6. Terrace level fire pump capacity of 900lpm is provided but not functional.
7. Terrace level fire water tank capacity of 10,000ltrs is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.
8. Exit signage's and floor signage found removed at strategic location in the restaurant building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of restaurant is at your own risk & responsibility.

Yours faithfully

  
(Am Garg)  
Director  
Ph: 011-23414000