

c/79

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/NDZ/2024/ 344

Dated: 21/06/2024

To

Mr. Rajeev Chauhan (Authorised Signatory),
Blue Ridge Retails Private Limited,
Kashmere Gate Metro Station, Delhi - 110006.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s **Blue Ridge Retails Pvt. Ltd. (PD Area)** situated at **Kashmere Gate Metro Station, Delhi - 110006.**

Sir,

This has reference to letter outdoor diary no. 2047 dated 24.05.2024 on the subject cited above. In this connection, it is to inform you that the site was visited by the team of officers concerned from this department on 10.06.2024 in the presence of Mr. Rajeev Chauhan (Site Officer) and it was observed that building is comprised of Ground + 02 upper floors but proposed PD area at ground floor only. During inspection, following shortcomings were observed:

1. 06 mtrs. access to building found encroached with private buses/ steel pillars.
2. Some hidden hydrant alongwith hose box and hose reel should be shifted out from outlet to corridor at ground floor.
3. Automatic sprinkler system should be provided in left out areas at ground floor.
4. Exit signages are not adequately provided.
5. All the outlet (assembly outlets) which exists at ground floor (Eldeco junction) & acquire space more than 90 square meter shall be directed to obtain their own FSC separately from this department, through MHA portal.

In view of above shortcomings, the application for issuance for renewal of Fire Safety Certificate is rejected.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


(Atul Garg)

Director o/c

Delhi Fire Service

Tel: 011-23414000

Copy to:-

1. The Dy. GM, DMRC PD Section-23, Ashoka Road, Near Patel Chock Metro Station, New Delhi.
2. Sh. Rajesh Kumar, AGM Project, 201-212, 2nd floor, ELDECO Splendor Forum, Jasola Distt. Central, New Delhi.