



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 349

Dated: 21/06/2024

To

The Principal
Jyoti Model Sr. Sec. School
C-18, Adarsh Nagar , Delhi-110007.

Sub: Regarding renewal of fire safety certificate in r/o Jyoti Model Senior. Secondary School at C-18, Acharya Kriplani Road, Adarsh Nagar, Delhi-110033.




Sir,

Please refer to your letter received through online e-mail dated 14.06.2024 on the subject cited above. In this connection this is to inform you that the above mention school building was inspected by the officer concerned of this department on 16.06.2024 in the presence of Sh. Vikas Gulati (Principal) was also present at site to check the existing fire safety & means of escape measures. During inspection it has been observed that the school building is comprised of ground & 02 upper floors only. The observations/ shortcomings made are as under:-

1. Terrace level fire pump not on auto mode.
2. Terrace level fire water tank 6,000ltr found provided against the requirement of 10,000ltr.
3. Exits signage's found removed at strategic location in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully


(Atul Garg)
Director
Ph:-011-23414000



Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.